

PRODUCT CHANGE NOTICE

Dear Valued Lantronix Customer,

The purpose of this communication is to inform you of an upcoming change to the following product. This change is part of our effort and commitment to continuous improvement of our products and processes.

Change Type

Software

Product Affected

Part Number	Description	Old Revision	New Revision
XSDR22000-01	2 PORT INDUSTRIAL AUTOMATION DEVICE SERVER, RoHS	G21	H21
XSDRIN-03	XPRESS DR-IAP, INDUSTRIAL DEVICE SERVER WITH INSTALLABLE INDUSTRIAL PROTOCOL, DIN-RAIL MOUNT, SERIAL INTERFACE, 10BASET/100BASE-TX, 9-30VDC/9-24VAC, ROHS	D12	E12
XSDRSN-03	XPRESS DR, INDUSTRIAL DEVICE SERVER, DIN-RAIL MOUNT, SERIAL INTERFACE, 10BASET/100BASE-TX, 9-30VDC/9-24VAC, ROHS	D12	E12

Description and Extent of Change

Lantronix is pleased to announce the release of Application Firmware version 7.0.0.3 and Web Manager version 2.0.0.13.

BUG FIXES:

- Change baudrate of Channel 1 on the fly via Telnet
- Cobos: update copyright information to 2021
- By default SNMP need to disabled across all cobos products

For customers that would like to take advantage of the new capabilities immediately, the new firmware, associated release notes and upgrade instructions is available for download from our website, <http://www.lantronix.com/support/downloads>.

Effect of Change on Fit, Form, or Function

Functional changes as noted above.

Effective Date of Change

This change will go into effect for the listed products built from **October 4, 2021** onwards.

If you have any questions, please contact your sales representative or Lantronix Technical Support at (800) 422-7044 or (949) 453-7198.